

Cooling Tower 1 Basin

	Date	pH (SU)	Temperature (°C)	Conductivity (umhos/cm) *	Dissolved Oxygen (mg/L)	Turbidity (NTU)
Before Vulcan -->	07-16-2013	8.46	26.7	7.22	3.56	0.1
After Vulcan -->	07-25-2013	8.67	26.9	7.35	3.26	0.1
	08-01-2013	8.32	27.5	7.2	3.33	0.1
	08-09-2013	7.97	27.9	7.59	3.36	0.1
	08-12-2013	8.67	27.7	7.29	3.6	0.1
	08-16-2013	8.56	27.5	7.16	3.52	0.1
	08-20-2013	8.47	26.4	7.2	3.31	0.1

* divided by 100 to fit within the chart scale

