

Cooling Tower 2 Basin

	Date	pH (SU)	Temperature (°C)	Conductivity (umhos/cm) *	Dissolved Oxygen (mg/L)	Turbidity (NTU)
Before Vulcan -->	07-16-2013	7.97	26.4	7.96	4.3	0.1
After Vulcan -->	07-25-2013	8.56	26.3	7.29	3.52	0.1
	08-01-2013	8.67	27.9	7.76	3.56	0.1
	08-09-2013	8.44	26.4	7.35	3.96	0.1
	08-12-2013	8.73	26.3	8.28	4.3	0.1
	08-16-2013	8.5	28.3	7.46	3.26	0.1
	08-20-2013	8.52	27.2	7.53	3.52	0.1

* divided by 100 to fit within the chart scale

